

Pleasant View Water

Annual Consumer Confidence Report

2024

ID #679503

We are pleased to present to you the 2024 Annual Drinking Water Quality Report. This report contains information regarding Pleasant View Water ID 679503. This report is designed to inform you about the quality of water and services we deliver to you every day. Our goal is to provide you with safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water distribution process and protect our water resources.

Pleasant View Water operates a small class-A water system. We are proud of the operations of the system, and we welcome this opportunity to tell you about it. We want you to know where your drinking water comes from and how it is treated. More importantly, we want you to know your water is safe to drink and meets or exceeds all government standards. This information allows people, particularly those with special health needs, to make informed decisions about their drinking water.

When congress passed the 1996 Safe Drinking Water Act amendments the Environmental Protection Agency (EPA) mandated that all public water systems provide notice of its annual water quality report. We are committed to ensuring that the quality of your water meets the highest attainable standards.

We have tried to make this report easy to understand, however, drinking water quality is a complex issue and some of the information is technical. If you have questions please contact Quality Water Care, Inc. (360) 387-7000.

WATER SOURCE

Our system pumps groundwater from an Island County aquifer and transmits the water to the reservoir. The water is chlorinated at the treatment plant, to minimize the risk of any coliform bacteria growing in your system.

TERMINOLOGY

Maximum Contaminant Level Goal (MCLG) - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL) - the highest level of contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.

Action Level (AL) – the concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.

Parts per million (ppm) or Milligrams per liter (Mg/l) – one part per million corresponds to one minute in 2 years or one penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (Ug/l) – one part per billion corresponds to one minute in 2,000 years or one penny in \$10,000,000.

Pleasant View Water
Annual Consumer Confidence Report
2024
ID #679503

WATER QUALITY TABLE

The information set out in the table is based on tests conducted during 2024 unless otherwise noted.

Contaminant	Test Date	Unit	MCL	MCLG	Number of samples that tested negative	Source	Violation
Bacteria	Monthly 2024	N/A	N/A	N/A	11	Naturally present	No
Nitrate	Sept 2024	PPB	10	10	0.80	Runoff – fertilizers, natural deposits septic tanks	No
THM & HAA5	Sept 2024	Ug/L	60 / 80	60 / 80	All ND or under MCL	Primarily occurs when disinfectants react with naturally occurring organic matter in the water.	No

NOTE: Bacteria sample from May 2024 tested positive for total coliform – all DOH required repeat bacteria samples passed with no presence of total coliform.

SUBSTANCES EXPECTED TO BE IN DRINKING WATER

To ensure that tap water meets acceptable drinking standards, the US EPA (Environmental Protection Agency) prescribes regulations limiting the amount of certain contaminants that may be in drinking water. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from the presence of animals or from human activity. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some of these contaminants. However, their presence does not necessarily mean that the water poses a health risk. Such substances may include:

Microbial contaminants, such as bacteria and viruses, may come from sewage treatment plants, septic systems agricultural livestock, or wildlife. These are tested monthly.

Inorganic contaminants, such as salts and metals, can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, mining, or farming. These are tested based on a schedule prescribed by the state Department of Health (DOH); they include nitrates, which are tested annually.

Pesticides and Herbicides may come from a variety of sources such as agriculture, stormwater runoff and residential uses. These are tested based on a schedule prescribed by the DOH.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals which are by-products of industrial processes, gas stations, storm water runoff and septic systems. These are tested based on a schedule prescribed by the DOH.

Radioactive contaminants, which are usually naturally occurring. These are tested based on a schedule prescribed by the DOH.

Pleasant View Water

Annual Consumer Confidence Report

2024

ID #679503

VIOLATION

The state required Gross Alpha and Radium 228 were not collected during the compliance period and are now past due. In addition, the county requires that we collect electrical conductivity and chloride samples in the spring and fall of every year. Our previous management company did not collect these samples in 2024. We have since contracted with Quality Water Care who will be collecting all mentioned samples in 2025

NITRATE

Nitrates in drinking water at levels above 10 ppm are considered a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

ARSENIC

Your drinking water currently meets EPA's revised drinking water standards for arsenic. However, it does contain low levels of arsenic, compared to the state MCL of 10 ppb. There is a small chance that some people who drink water containing low levels of arsenic for many years could develop circulatory disease, cancer, or other health problems. Most types of cancer and circulatory disease are due to factors other than exposure to arsenic. The EPA's standard balances the current understanding of arsenic's health effects against the cost of removing arsenic from drinking water.

IRON AND MANGANESE

Typical of much of the Island's water, your water contains elevated levels of Iron and Manganese, which are abundant in the rocks and soils in the area. These are secondary contaminants, and the US EPA (Environmental Protection Agency) has not mandated treatment to reduce the levels of contamination. Scientific findings suggest that the levels found pose no threat to human health. Manganese and iron are considered an aesthetic problem. At sufficient concentrations, iron can adversely affect the taste of water and can leave rust-colored stains on laundry, plumbing fixtures and porcelain. Manganese can cause similar problems, has a bitter metallic taste and may leave black "specks" in ice cubes. Manganese can also produce staining and cause water to have a brown or black discoloration.

The Washington State Department of Health Office of Drinking Water (ODW) is modifying their recommendations for public water systems that have manganese in their water supply. For many years, manganese in drinking water was considered as only an aesthetic concern, causing discoloration and staining. However, recent studies show negative health effects from exposure to high levels of manganese in drinking water. They have used this new information to revise their guidelines, which are expected to be implemented in the coming years. Additional information can be found on the DOH website at [331-740 Manganese in Drinking Water: What Customers Should Know](#)

Pleasant View Water

Annual Consumer Confidence Report

2024

ID #679503

CONDUCTIVITY AND CHLORIDE

The system is tested twice a year for conductivity and chlorides; this is to ensure that our water source is not being contaminated by salt water. This is a county requirement. Levels are set out below: PLEASE NOTE: Our previous management company did not collect the required tests in April or in August. We have since contracted with Quality Water Care who fulfilled the August testing requirement.

Contaminant	Test Date	Unit	MCL	MCLG	Result	Source
SOI						
Chloride	April & Aug 2024	Mg/l	250	250	None Collected	Salt water or natural deposits
Conductivity	April & Aug 2024	Umhos/cm	700	700	None Collected	

LEAD AND COPPER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

REPAIRS AND MAINTENANCE – SHARED RESPONSIBILITIES

Sometimes problems occur associated with snow, freezing weather, heavy rains, and flooding – all of which can cause water pipes to break and necessitate the need to get the water turned off in an emergency. Please remember that it is the responsibility of your water system (the purveyor) to deliver safe drinking water to your property. As a rule, this responsibility stops at the meter or shut-off valve – usually located at, or close to, the property line. However, **it is the responsibility of the homeowner to know where their shut-off valve is located and to keep the area clear and readily accessible.**

ADDITIONAL HEALTH INFORMATION

Some people may be more vulnerable to contaminants in drinking water than the general population. They include immuno-compromised persons such as persons with cancer, those undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, the elderly, and infants, who can be particularly at risk from infections. These people should seek advice from their health care providers before drinking any water. More information about EPA/CDC guidelines to lessen the risk of infection by Cryptosporidium, other contaminants and potential health effects can be obtained by calling the Environmental Protection Agency Safe Drinking Water Hotline (800-426-4791).

Pleasant View Water
Annual Consumer Confidence Report
2024
ID #679503

IMPORTANT NOTICE

Water services in your water system may have been installed with, or upgraded to include a check valve that helps protect the water system from a backflow event. This occurs when a drop in pressure in the mains allows water to be drawn into the mains from the service connection; as a result, the system water can be contaminated.

The installation of the check valve causes the home to become a “closed system” and makes it susceptible to damage caused by thermal expansion of the water. Thermal expansion takes place in water heaters when water is heated. As the water is heated, it expands and increases in volume. Traditionally, the increased volume of water flows back into the supply line and into the public water supply main. With the addition of backflow preventers, check valves, and pressure-reducing valves on the supply line, a closed loop is formed, and the water cannot flow back into the supply line. The volume of water then increases, and the resultant pressure increases beyond what the hot water system is designed to handle. The increase in pressure causes the emergency relief valve on the water tank to open and discharge water creating a nuisance and resulting in inefficient operation. Excessive pressure may also rupture pipe fittings and lead to water heater explosions. To eliminate this potential hazard, the owner must install pressure relief valves or accumulators in the plumbing system to relieve pressure. Please ensure that your water heater has been properly installed with working protection devices (T&P valve and expansion tank); if in doubt, consult with your plumber.

For more information about this report, or for any questions you have about your drinking water, please contact:

Quality Water Care, Inc. (360) 387-7000

